

Blow-out times for automatic fuses

Code	Fuse	100% (A)	150% (A)	200% (A)
89201	50A	30-60S	15-30S	5-10S
89202	100A	30-60S	10-15S	5-10S
89203	200A	15-30S	10-15S	2-5S

100% (A) – current according to the fuse

150% (A) – current 1,5 times higher than the fuse

200% (A) – current 2 times higher than the fuse

S - (seconds) time after the fuse blow out